

DEPARTMENT OF HEALTH

Division of Environmental Health Onsite Sewage and Water Section 10777 Main Street, Suite 102 Fairfax, Virginia 22030-6903

Telephone: (703) 246-2201 Fax: (703) 278-8157

TDD: (703) 591-6435

December 2, 2004

Sasan Ahmadiyar Dos 7806 Sudley Road, Suite 210 Manassas VA 20109

RE:

Soil Evaluation for Subsurface Sewage Disposal at 8228 Shadowridge Drive, Fairfax Station

TM: 96-3-005-16; Date of Test: 11-15-2004

Dear Mr. Dos:

Soil percolation tests and other soil studies on the above referenced lot were satisfactory with a rate of 10 at 65 inches depth. Issuance of a Sewage Disposal System Construction Permit is subject to the following requirements:

- 1. Sufficient land area available in the approved area for the required individual sewage disposal system.
- This approved footprint is for a 50% replacement area of existing sewage disposal system.
- Dimensional plot plan showing the house location and all required information.
- 4. Review and approval of the building permit application.
- 5. Any grading or physical alterations of the property may invalidate the approval for an individual sewage disposal system.
- Where public water is not available, approval is subject to proper location of a well in accordance with applicable State and County Regulations.
- 7. There appears to be adequate area for a <u>5</u> bedroom system.

Due to the variations in soil, in some instances it may be necessary to reappraise a particular lot. If further information is desired, please let us know.

Sincerely,

Kevin R. Wastler

Environmental Health Supervisor

KRW: nm

Encl: Plat

CC: Tax Assessments